



PIPE SHALL BE CENTERED UNDER INSULATION UNLESS OTHERWISE SPECIFIED.

COVER OVER PIPE - A

2'

3'

4'

5'

6'

WIDTH OF INSULATING BOARD - B

11'

9'

7'

5'

3'



STANDARD DETAILS

INSULATION DETAIL

COTTAGE GROVE, MINNESOTA

JANUARY 2022

PLATE NO.

WAT-9