



- NOTES:
1. TOP 1' OF PAD TO BE 24" X 24" SQUARE
 2. BOTTOM 24" OF PAD TO BE 24" CYLINDER FORMED WITH SONA TUBE
 3. A SECOND GROUNDING ROD IS TO BE LOCATED 6' AWAY FROM THE BASE WITH A #6 GROUNDING CONDUCTOR RUNNING TO IT WITHIN A 3/4" CONDUIT



STANDARD DETAILS
LIGHTING EQUIPMENT PAD

COTTAGE GROVE, MINNESOTA

JANUARY 2022

PLATE NO.
LGT-6